

CWSS TO BATLAGUNDU UTP AND 16 OTHER HABITATIONS

1. Scheme Cost	:	Rs. 346.54 Lakhs
2. Beneficiaries	:	Town Panchayat – 2 Nos. Habitations - 15 Nos.
3. Population	:	37288
4. Designed Qty	:	1.91 mld
5. Head works		
6. Source	:	Infiltration wells in River Vaigai
		Well – I Well-II Well – III
Dia	:	4.50 m 4.50 m 4.50 m
Depth	:	7.55 m 6.10 m 6.55 m
Pump set	:	3 HP 3 HP 3 HP
Duty	:	595 lpm x 11m 595 lpm x 11m 595 lpm x 11m
		Open well submersible – 5 Nos
Connecting Main 150 CI	:	108.35 m 145.65 m 212.75 m
7. Pump set Details	:	25 HP x 1450 lpm x 40 m – 2 Nos Centrifugal split casing pump set
8. Hours of Pumping	:	20 Hours
9. Pumping main details	:	250mm AC, 18860 m Branch Mains – 2184 m (63 mm PVC)
10. Booster station Location	:	Near Kulipatty
Pump set Details	:	30 HP x 1350 lpm x 52 m – 2 Nos Centrifugal split casing pump set
11. Service Reservoir	:	2,50,000 Lit. – 1 No. 6,25,000 Lit. – 1 No. 60,000 Lit. – 4Nos. 30,000 Lit. – 10Nos. 10,000 Lit. – 3Nos.

C.W.S.S to Batlagundu U.T.P and 16 Rural Habitations In Dindigul Distri

