

TAMIL NADU WATER SUPPLY AND DRAINAGE BOARD



ABSTRACT

TWAD BOARD - REPLACEMENT OF DAMAGED PIPES DUE TO WIDENING OF ROADS AND REPLACING THE EXISTING CHLORINATION SYSTEM IN TWAD MAINTAINED CWSS TO P.N.PATTY & VEERAKKALPUDUR TOWN PANCHAYATS IN SALEM DISTRICT. AT AN ESTIMATE COST OF RS.160.00 LAKHS UNDER OUTLIVED CWSS PROJECT OF CAPITAL GRANT FUND FOR 2017-18 ADMINISTRATIVE APPROVAL ACCORDED- ORDERS ISSUED-REG

(OPERATION AND MAINTENANCE WING)

B.P. Ms. No.30

Dated:18.04.2018

Read :

Board Circulation Resolution No.445/dated: 06.04.2018

ORDER:

During the Dr.M.G.R. Birth Centenary Celebrations held on 30.09.2017 at Salem, the Hon'ble Chief Minister has made an announcement for providing new Pipeline in CWSS to P.N.Patti and Veerakkalpudur Town Panchayats of Salem District based on the request of the local body since the pipelines are damaged due to road widening works carried out by the State Highways Department and hence water supply to the above beneficiaries is badly affected.

Accordingly the Chief Engineer, Coimbatore has submitted detailed estimate for Rs.160.00 lakh comprising of replacement of damaged AC pipes with DI, construction of roof slab by dismantling the damaged roof slab and replacing the existing chlorination system with vacuum feed gas chlorination.

The Combined Water Supply Scheme to P.N.Patti and Veerakkalpudur Town Panchayats in Salem District with River Cauvery as source was sanctioned for Rs.542.00 lakh to install and Rs.28.00 lakhs to maintain annually vide in G.O.Ms.No. 276/RD/WS1/Dt.31.12.1996. The CWSS was implemented and commissioned during 1999 and being maintained by Maintenance Division, Salem, since March 1999.

