

## SALIENT DETAILS

### CWSS TO OZHLUKARAI - KARUVEPPAMPOONDI IN UTHIRAMERUR UNION

1. Scheme cost : Rs 6.15 Lakhs  
2. Beneficiaries : 2 Habitations  
3. Population : 2700  
4. Designed quantity : 0.06 mld  
5. Head Works with source details : As detailed below

S.No	source	size in mm	Depth in m	Yield in lpm
1.	Borewell well	150	9.00	200

6. Pumpset

- Type : Submersible  
Duty : 5.00 HP 150 lpm x 55m head

- b. Sump Capacity : -----  
Hours of Pumping : 8 hours

7. Transmission main  
Pumping main

- 100mm G.I. Pipe : 340 m  
110mm PVC 4 Ksc Pipe : 1000 m  
90mm PVC 4 Ksc Pipe : 2200 m  
Gravity main : ---

8. Booster Station

- a. Sump with Capacity : ---

b. Pumpset Details

- Type :  
Duty :

- 9 . Feeder main : ---

10. Service reservoir with capacity.

Sl. No.	Name of Beneficiary	Name of Panchayat	S.R.Capacity
1	Ozucarai	Ozucarai	0.30LLD
2	Karuveppampoondi	Karuveppampoondi	0.30LLD

**CWSS TO OZHUKARAI AND KARUPEPPAMPOONDI IN UTHIRAMERUR UNION  
FLOW DIAGRAM**

