


TENTATIVE WATER BALANCE DIAGRAM FOR NLC MINE WATER TREATMENT PACKAGE

CUSTOMER : TWAD BOARD, CWSS PROJECT
PROPOSAL REFERENCE : 2020-D-14_Rev 3| Section 3 |June 18, 2020



Note :

1. The above flow rates are estimated. The guarantees shall be on the final product water quantity as provided in the technical offer.

2.. Distance between raw water storage tank & cascade aerator will be maximum 50 meters.