

WSIS TO BALASAMUDRAM TOWN PANCHAYAT IN DINDIGUL DISTRICT INTAKE WELL REINFORCEMENT DETAILS

10mm dia RTS 150mm/c at bottom radially and horizontally

10mm dia RTS 150mm/c at top radially and horizontally

10mm dia RTS 150mm/c as radial rod

3 Nos of 10mm dia RTS as circumferencial rod

10mm dia RTS 150mm/c vertically and horizontally on both faces

